

Schedule 411/02.S01 to Certificate 411/02

Schedule for Coopers SmokeStop Smoke Barrier

An active smoke curtain comprising a fabric curtain (fabric reference EFP 2/A2) mounted on single or twin rollers. Single units having maximum width of 6000mm and a maximum drop of 4000mm. Multiple con-joined curtains with a minimum 400mm overlap are allowed with no maximum number of units with the following limitations: Maximum width of individual unit 5000mm and a maximum drop of 10500mm. The curtain was evaluated in accordance with BS EN 12101-1: 2005+A1: 2006 and classified in accordance with BS EN 13501-4.

Classification to BS EN 13501-4

Temperature/time classification	DH60, D₆₀₀A
Reliability and response time	1000cycles, ASB1 and ASB3
Permeability to Smoke	<25m³/hr/m² at 25 Pa
Integrity	60 mins, 150 mins

Test evidence

Reports WARRES 198447/A, IFCC/100905, IFCC/411/100905, Efectis 10-V-428, 145693 Iss 2.



Ian Woodhouse
Director

Date first issued: 8 December 2010
Reissued: 16 March 2016
Revised: 20 April 2016
Valid to: 7 December 2021
Issue No.3

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.