



**PENETRATION & LINEAR GAP
SEALS SCHEME SDP13**
Certificate number: FS453/03

This is a product certificate to certify that

Pre-formed Components Ltd trading as

PFC Corofil

Units 3 & 4
King George Trading Estate
Davis Road
Surrey
KT9 1TT
Telephone no. +44 (0) 208 391 0533
www.pfc-corofil.com

Who manufacture the following system:

PFC Corofil Ablative Coating

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 20 and EN1366-3**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to 4 hours fire resistance are detailed in the schedule referenced below.



Schedule ref: FRTD453/S03
First Issued: 20 November 2007
Revalidated: 19 November 2017
Valid to: 18 November 2022
Issue No: 4



175

A handwritten signature in black ink, which appears to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.