



**PENETRATION & LINEAR GAP  
SEALS SCHEME SDP13**  
*Certificate number: FS453/08*

This is a product certificate to certify that

*Pre-Formed Components Ltd trading as*

**PFC COROFIL**

Units 3 & 4  
King George Trading Estate  
Davis Road  
Surrey  
KT9 1TT  
Telephone no. +44 (0) 208 391 0533  
[www.pfc-corofil.com](http://www.pfc-corofil.com)

Who manufacture the following system:

**PFC Corofil Intumescent sheet for the production of  
C500**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 20**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to 4 hours fire resistance are detailed in the schedule referenced below.



Schedule number: FS453/S08  
Initial registration: 20 November 2007  
Revalidated: 19 November 2017  
Valid to: 18 November 2022  
Issue status: 4



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse**  
Director of Certification

---

IFC Certification Ltd  
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.