



FIRE RESISTANT STEEL DOORS

Certificate number: IFCC1168

This is a product certificate to certify that

Al Kuhaimi Metal Industries Ltd

P.O. Box 545
Street 11
First Industrial Area
Dammam 31421
Kingdom of Saudi Arabia
+ 966 1384 72777

Who fabricate the following hollow metal fire doors:

Al Kuhaimi Single, Double, solid and glazed steel doorset (door and frame) with seamless edge construction

Single Leaf:- 1488mm wide x 2807mm high x 45mm thick

Double Leaf:- 1397 (x2)mm wide x 2817mm high x 45mm thick

Over panel/Glazed:- 500mm high x width of the door set

Side panel/Glazed:- 1398mm wide x height of the door set

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve 180 minutes **integrity** are detailed in the schedule referenced below.



Schedule ref: IFCC1168/A01149 Rev D

First Issued: 6th October 2015

Valid to: 5th October 2020

Issue No: 2

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.