



FIRE RESISTANT GLAZED SCREENS

Certificate number: IFCC1169

This is a product certificate to certify that

Al Kuhaimi Metal Industries Ltd

P.O. Box 545
Street 11
First Industrial Area
Dammam 31421
Kingdom of Saudi Arabia
+ 966 1384 72777

Who fabricate the following hollow metal glazed screen:

Uninsulated steel framed glazed window using 6mm Pyran S

*3600mm wide x 1200mm height with a maximum clear glazed area of
(1083mm wide and 1050mm high)*

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve 120 minutes **integrity** are detailed in the schedule referenced below.

Schedule ref: IFCC1169/PAR/12400/02



First Issued: 6th October 2015
Valid to: 5th October 2020
Issue No: 2



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.