



FIRE RESISTANT STEEL DOORS

Certificate number: IFCC1242

This is a product certificate to certify that

Al Kuhaimi Metal Industries Ltd

P.O. Box 545, Street 11
First Industrial Area
Dammam 31421
Kingdom of Saudi Arabia
+ 966 1384 72777

Who fabricate the following fire doors:

***Single/Double Leaf, Polyurethane &
Honeycomb infilled steel door assemblies***

***Single Leaf:- 1300mm wide x 2950mm high x 45mm thick
Double Leaf:- 2604mm wide x 2950mm high x 45mm thick***

Have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve 90 minutes **integrity** are detailed in the schedule referenced below.

Schedule ref: IFCC1242/PAR_15606_01 Rev A



First Issued: 16th June 2016
Valid to: 15th June 2021
Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.