



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1025

This is a product certificate to certify that

Bahwan Contracting Co. LLC

PO Box 1098
Ruwi, Postal Code 112
Muscat
Sultanate of Oman
Tel no. +968 24591091/92/93
Email: civil@becoman.com

Who fabricate the following fire doors:

**Strebord FD30; Warm Springs FD90; Kingsa FD30; Kingsa FD90
Strebord FD60; Warm Springs FD120; Kingsa FD60; Kingsa FD120
BCC FD60**

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedule referenced below.

Schedules ref: SS01, SS02, WS02,
KS01, KS02, KS03, KS04, IFCC 1025/S01



First Issued: 2 July 2013
Reissued 20 June 2018
Valid to: 19 June 2023
Issue No: 3



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.