



Date : 13th September 2017

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	RC138-A	CERTIFICATE NUMBER	IFCC 1318
DATE OF ISSUE	10 th July 2017	DATE OF ISSUE	7 th September 2017
DATE OF EXPIRY	No specified expiry date	DATE OF EXPIRY	6 th September 2022
Manufacturer details			
NAME OF FACTORY / MANUFACTURER	Eagle Steel Industries FZC	NAME OF THE BRAND	Single Steel Glazed Doorset
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Sharjah - UAE P.O. Box 53729 UAE	MODEL / NO	N/A
WEBSITE	www.eaglesteelindustries.com		 IFCC Certification Ltd Tel: +971 584 27500 Fax: +971 584 27602 Email: info@icccertification.com Web: www.icccertification.com
TEL	+971 50 93 45 514	EMAIL	info@eaglesteelindustries.com



Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITYETC)	FD240 Latched single acting single leaf steel doorset with vision panel. The overall dimensions of the doorset was 2503 x 1406 x 150mm (h x w x jamb depth).	Page 5 of 30
TEST STANDARD (SUCH AS ASTM/BS EN/ DNETC)	BS 476 Part 22:1987 Fire Tests on Building Materials and Structures – Part 22: Methods for Determination of the Fire Resistance of Non-load bearing Elements of Construction. Doorset has been evaluated in accordance with Section 7: Determination of the Fire Resistance of Partially Insulated Doorsets and Shutter Assemblies.	Page 4 of 30
TEST DESCRIPTION	<p>The restraint frame was made of steel and refractory castable with an opening of 3050 x 3050 mm (wxh) was filled using solid concrete blocks of thickness 200mm and density of 2000kg/m³ to provide an opening of 2508 x 1416mm (h x w) for the doorset. A 200 x 150mm (depth x h) reinforced concrete lintel was used at the head of the opening.</p> <p>The doorset was installed with the leaf opening away from the furnace, as decided by the sponsor of the test. Note that the fire door may behave differently depending on which side is exposed to fire.</p> <p>A door closer was installed on the exposed face of the doorset as decided by the sponsor of the test. The door closer had an average closer retention force of 96.14N.</p> <p>The door was latched but not locked. The doorset had a latch throw of 11.37mm and engaged an average of 8.66mm into the latch catch.</p> <p>A door handle was installed on either face of the door and a double lock cylinder was installed on the door leaf visible from either side.</p> <p>The time-temperature curve was controlled using the 9 thermocouples distributed in the furnace. The thermocouples were placed at 100mm from the exposed face of the specimen.</p> <p>The ambient temperature at the start of the test was 35 Degs C.</p> <p>The pressure in the furnace was controlled at 12 Pa at its relative position in the furnace, in accordance with paragraph 3.2.2 of BS 476-20:1987.</p> <p>Deflections and unexposed face temperatures were measured and recorded during the test.</p>	<p>Page 5 of 30</p> <p>Page 6 of 30</p>



SPECIFICATION OF TEST SPECIMEN	<p>Door Frame Material: Galvanised Steel Fabricator: Eagle Steel Industries FZC. Dimensions: 2503 x 1406 x 150mm (h x w jamb depth) Fixing method: The frame was fixed to the supporting construction using counter-sunk expansion bolts of size dia10 x 72mm (dia x l) at a distance of 645mm c/c spaced nominally and 150mm from either ends of the vertical jambs.</p>	Page 9 of 30
	<p>Door Leaf Material: Galvanised Steel Dimensions: 2453 x 1306 x 45mm (h x w x thk)</p>	Page 10 of 30
	<p>Glazing System Glass: Keralite Glass Manufacturer: Vetrotech Saint-Gobain Dimensions: 482 x 482 x 5mm (h x w x thk) Quantity: 1 off Tape: Calcium magnesium Silicate (Kerafix 2000) Manufacturer: Vetrotech Saint-Gobain Setting Blocks: Calcium Silicate 5 x 80mm (w x l) two pieces placed along the bottom edge of the glass pane. Manufacturer: Vetrotech Saint-Gobain</p>	Page 12 of 30
	<p>Ironmongery Hinges Material: Stainless Steel Manufacturer: EUROART Ref: HINBB433-SSS Dimension: 102 x 76 mm (l x w) Quantity: 4 off Fixing Method: Screwed to the frame and leaf using machine screws at a nominal distance of 674mm c/c nominally and 199 mm from the bottom end and 127mm from the top end.</p>	Page 13 of 30
	<p>Mortise Lock Material: Stainless Steel Manufacturer: EUROART Ref: DLA7255EP Dimension: 102 x 76 mm (l x w) Fixing Method: As per manufacturer's instructions.</p> <p>Mortise Lock Reinforcement Material: Mild Steel Manufacturer: Eagle Star Industries FZC Dimension: 57 x 32 x 2.7mm (l x w x thk) Fixing Method: Welded onto the latch stile inner edge of the door leaf.</p> <p>Lock Cylinder Material: Satin Nickle Finish Manufacturer: EUROART Ref: CYD145 Fixing Method: As per manufacturer's instructions.</p>	Page 14 of 30



	<p>Door Handle Material: Stainless Steel Manufacturer: EUROART Ref: LRS101 Fixing Method: As per manufacturer's instructions.</p> <p>Overhead Door Closer Material: Stainless Steel Manufacturer: EUROART Ref: DC5024 Fixing Method: As per manufacturer's instructions.</p>	
<p>TEST RESULT (SUCH AS PASSED CRITERIA ___/ COMPLIED TO ___/ DURATION ___/OBSERVATION ___/ETC)</p>	<p>Integrity – 240 minutes Insulation – 18 minutes</p>	<p>Page 7 of 30</p>
<p>PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN ___/TO BE INSTALLED AT ___/TO BE CONNECTED WITH ___/TO BE INSTALLED WITH ___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN ___/NOT TO BE INSTALLED AT ___/ NOT TO BE INSTALLED WITH ___ ETC.</p>	<p>The results relate only to the behavior of the specimen of the element of construction under particular conditions of test. They are not intended to be the sole criteria for assessing the potential fire performance of the element in use nor do they reflect the actual behavior in fires.</p> <p>The test results relate only to the specimen tested. Application of the results to door sets of different dimensions or supported other than by a masonry wall or incorporating different components should be the subject of a design appraisal.</p>	<p>Page 8 of 30</p>






Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	IFC Certification	NAME OF TEST FACILITY	Thomas Bell-Wright International Consultants
CERTIFICATION BODY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK	TEST FACILITY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Corner of 46 th and 47 th streets, Jebel Ali Ind Area 1, P.O.Box 26385 Dubai, U.A.E.
WEBSITE	www.ifccertification.com	WEBSITE	http://www.bell-wright.com/
TEL	+44 (0)1844 275500	TEL	+971 (0) 4 821 5777
EMAIL	info@ifccertification.com	EMAIL	admin@bell-wright.com
ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)</small>	UKAS (United Kingdom Accreditation Service)	ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)</small>	- UKAS Testing Laboratory No. 4439. www.ukas.com - GCC Testing Lab: ATL-0017 www.GCC-accreditation.org
AS PER <small>(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)</small>	ISO/IEC 17065	AS PER <small>(STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)</small>	ISO/IEC 17025
VALIDITY <small>(EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)</small>	N/A	VALIDITY <small>(EXPIRY DATE OF LABORATORY ACCREDITATION)</small>	N/A
REFERENCE NUMBER: <small>(CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small>	IFCC accreditation No. 0175	REFERENCE NUMBER: <small>(THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small>	4439 ATL-0017
CERTIFICATION MARK			



(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER

NAME OF MANUFACTURER'S SIGNATORY		SIGNATURE	
EMAIL / TEL		FACTORY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY

NAME OF CERTIFICATION BODY SIGNATORY	Ian Laithwaite Reviewed by: Ian Woodhouse	SIGNATURE	 
EMAIL / TEL	lan.laithwaite@ifcgroup.com	CERTIFICATION BODY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)