



FIRE RESISTANT METAL BASED DOOR SCHEME

Certificate number: IFCC 1318

This is a product certificate to certify that

Eagle Steel Industries FZC

Sharjah - UAE

P.O. Box 53729

UAE

Tel +97150 9345514

+97150 9345519

who fabricate the following steel fire doorsets:

FD240 Glazed Single Leaf Metal Based Doorset
FD180 Unglazed Single/Double Leaf Metal Based Doorset

have satisfied the requirements of the SDP02 Fire resistant metal based door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 240 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: IFCC1318/SO1, IFCC1318/SO2



Initial certification: 07 September 2017

Valid to: 06 September 2022

Issue status: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse', is written over a light-colored background.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.