



## **FIRE RESISTANT TIMBER FIRE DOORS**

***Certificate number: IFCC1165***

This is a product certificate to certify that

### ***PCM DESIGN SRL***

Via 1 Maggio,  
156 – Ancona,  
ITALY  
+39 071 7506030

Who fabricate the following fire doors:

***Sauerland FD30 Sauerland FD60***  
**Halspan FD30 Halspan FD60 Halspan FD90 Halspan FD120**  
**Halspan EI30 Halspan EI60**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22 or EN1634-1: 2000**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: PAR/13211/01, PAR/13211/02, HS01, HS02, HS03, HS04, HS05, HS06,  
IFCA/15953/01 & IFCA/15953/02



First Issued: 30<sup>th</sup> September 2015  
Revised: 25<sup>th</sup> January 2018  
Valid to: 29<sup>th</sup> September 2020  
Issue No: 2



175

A handwritten signature in cursive script, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.