



Schedule No: FRD600a/S08

to

Certificate no: FRD600a

Firemac Ltd

Product range

Firemac FM120S Systems

2 hrs Fire Resistance (Integrity, Stability and Smoke Extract) of a Duct Type A and B
BS 476: Part 24: 1987 (ISO 6944: 1985)

Manufacturing locations: A-AB13

The application of this product should be carried out following the manufacturers' instructions and according to the following document:

BRE Assessment Report No. P101930-1002
Branz Assessment Report No. FC10778-001

This schedule must be read in conjunction with BRE Assessment Report No. P101930-1002 and all aspects of the specification and limitations defined therein must be satisfied. Failure to comply with all specifications will invalidate the approval, and may jeopardise the fire performance.



Ian Woodhouse
Director of Certification

Date 2nd October 2016
Revised 2nd November 2018

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd