



## **FIRE RESISTANT TIMBER FIRE DOORS**

***Certificate number: FRTD497***

This is a product certificate to certify that

### ***Forza Doors Limited***

Star Road Trading Estate  
24a/24c Star Road  
Partridge Green, Horsham  
West Sussex, RH13 8RA  
Tel: +44 (0)1403 711126  
Fax: +44 (0)1403 711229  
Email: technical@forza-doors.com

Who manufacture the following fire doors & door sets

**FORZA FD30 & FD30S Flush Doors**  
**FORZA FD60 & FD60S Flush Doors**  
**FORZA FD90 Flush Doors & FORZA FD120 Flush Doors**

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: PAR/10321/01, PAR/10896/01, PAR/10918/01 & PAR/10922/01



First Issued: 25 November 2010  
Revised: 20 March 2019  
Valid to: 24 November 2020  
Issue No: 6

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.