



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: FRTD 531

This is a product certificate to certify that

Al Amara Trading

P O Box 3783

Doha

Qatar

Tel no.: +974 44 600 620

+974 44 600 200

Who fabricate the following fire doors:

Halspan FD30, Halspan FD60, Halspan FD90, Halspan FD120

FireBan FD30, FireBan FD60, FireBan FD90, FireBan FD120

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01, HS02, HS03, HS04, HS05, HS06, GTL S03, GTL S04



First Issued: 1 January 2011

Re-issued: 06 January 2017

Valid to: 31 December 2020

Issue No: 4



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.