



## Product Certification Scheme Fire Shutters & Barriers SD06

***Certificate number: FSB 411***

This is a product certificate to certify that

### ***Coopers Fire Ltd***

Edward House,  
Penner Road  
Havant, PO9 1QZ  
UK

who fabricate the following product:

### ***FIREMASTER™ Fire Barrier Uninsulated Drop Curtain***

have satisfied the requirements of the above scheme. This includes the initial type testing of products to **BS476: Part 22** and **EN1634-1**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **240 minutes to BS 476: Part 22 and 120 minutes integrity to EN1634-1** are detailed in the schedules referenced below.



Schedule ref: FSB/411/S04 & S05

First Issued: 17 January 2006

Reissued: 31 March 2016

Revised: 2 August 2012

Valid to: 20 April 2021

Issue No: 6



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification

---

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.