



PRODUCT CERTIFICATION SCHEME – SMOKE CURTAINS

Certificate number: FSB 411/02

This is a product certificate to certify that

Coopers Fire Ltd

Edward House
Penner Road
Havant
Hampshire PO9 1QZ

Who fabricate the following smoke curtains:

SmokeStop Smoke Barrier

have satisfied the requirements of scheme SDP07 which encompasses the requirements of **BS EN 12101-1: 2005+A1: 2006**. This includes the type testing of product, the inspection of the Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product is classified as **DH60 Integrity 60 mins, D_{600A} Integrity 150mins**. Further details are contained in the Schedule referenced below.



Schedule ref: 411/02.S01
First Issued: 8 December 2010
Re-issued: 16 March 2016
Revised: 06 December 2016
Valid to: 7 December 2021
Issue No: 5



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.