



FIRE RESISTANT METAL DOORS

Certificate number: IFCC 1324

This is a product certificate to certify that

A1 Shutters Ltd

Jackson Works, Raikes Lane Industrial Estate,
Raikes Lane, Bolton BL3 2NH
United Kingdom

Tel: 01204 383839 Fax: 01204 381686

Email: sales@A1shutters.co.uk

Uninsulated Fire Roller Shutters

have satisfied the requirements of the SDP02 Metal Fire Door scheme. This includes the testing of products to **BS EN 1634-1**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **up to 240 minutes** integrity are detailed in the schedules referenced below.



Schedule ref: IFCC 1324/S01

First Issued: 6th October 2017

Revised: 30th January 2020

Valid to: 5th October 2022

Issue No: 2



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.