



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1069

This is a product certificate to certify that

Alshajarah Carpentry & Decoration

P O Box 82614
Doha
Qatar
Tel No. +97440174034

Who fabricate the following fire doors:

Bertas FD30	Bertas FD60	Halspan FD30	Halspan FD60
Halspan FD90	Halspan FD120	Strebord FD30	Strebord FD60
FireBan FD30	FireBan FD60	FireBan FD90	FireBan FD120
Ramkor FD90			

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01, HS02, HS03, HS04, HS05, HS06, PAR/13781-01, SS01, SS02, RA01, GTL/S03, GTL/S04



First Issued: 16 December 2013
Revised: 6 June 2018
Valid to: 15 December 2018
Issue No: 6

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.