



# FIRE RESISTANT TIMBER FIRE DOORS

***Certificate number: IFCC 1069***

This is a product certificate to certify that

## ***Alshajarah Carpentry & Decoration***

P O Box 82614  
Doha  
Qatar  
Tel No. +97440174034

Who fabricate the following fire doors:

<b>Halspan FD30</b>	<b>Halspan FD60</b>	<b>Ramkor FD90</b>	
<b>Halspan FD90</b>	<b>Halspan FD120</b>	<b>Strebord FD30</b>	<b>Strebord FD60</b>
<b>FireBan FD30</b>	<b>FireBan FD60</b>	<b>FireBan FD90</b>	<b>FireBan FD120</b>

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01, HS02, HS03, HS04, HS05, HS06, SS02, RA01, GTL/S03, GTL/S04



First Issued: 16 December 2013  
Reissued: 07 January 2019  
Revised: 11 January 2019  
Valid to: 15 December 2023  
Issue No: 8



175

Ian Woodhouse  
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.