



## **FIRE RESISTANT TIMBER FIRE DOORS**

***Certificate number: IFCC1035***

This is a product certificate to certify that

### ***Dana Palace Decoration & Trading Co.***

PO Box 2971  
Industrial Area, St. 30 Gate 28  
Doha Qatar  
Telephone no. +974 4450 3624

### **Halspan FD30; Halspan FD60; Halspan FD90; Halspan FD120 FireBan FD30; FireBan FD60; FireBan FD90**

have satisfied the requirements of the IFCC SDP01 scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01, HS02, HS03, HS04,  
HS05, HS06, GTLS03



First Issued: 5 September 2013  
Reissued: 7 September 2018  
Valid to: 4 September 2023  
Issue No: 2



**175**

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse  
Certification Director**

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.