



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1021

This is a product certificate to certify that

Galfar Engineering & Contracting SAOG

PO Box 533
PC100
Muscat
Sultanate of Oman
Telephone no. +968 2452 5039

Who fabricate the following fire doors:

Kingsa FD30 Kingsa FD60 Kingsa FD90
Galfar FD60 Galfar FD90

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **30 minutes to 90 minutes integrity** are detailed in the schedule referenced below.

Schedule ref: KS01; KS02; KS03;
IFCC1021/S01



First Issued: 8 July 2013
Re-issued 29 November 2018
Valid to: 7 July 2023
Issue No: 3



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.