



FIRE RESISTANT STEEL DOORS

Certificate number: IFCC 1098

This is a product certificate to certify that

Bonfire Shield

PO Box 3551
Doha Qatar
Telephone no. +974 4412 8211

Who fabricate the following fire doors:

**BSH FD180 Latched Single Leaf Single Acting Steel
Door with Vision Panel**

**BSH FD240 Latched Unequal Double Leaf Single
Acting Steel Door without Vision Panel**

have satisfied the requirements of the **IFCC Scheme SDP 02**. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications to achieve **180mins** and **240 mins integrity** are detailed in the schedule referenced below.



Schedules ref: IFCC 1098/S01

First Issued: 22 July 2014
Reissued: 09 September 2019
Revised: 09 December 2019
Valid to: 21 July 2024
Issue No: 4



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.