

PRODUCT CERTIFICATION SCHEME SDP11-02

Certificate number: IFCC 1161

This is a product certificate to certify that

Coopers Fire Ltd.

Edward House, Penner Road, Havant,
Hampshire, PO9 1QZ, United Kingdom

Who fabricate the following product:

Product:	FireMaster® A1 Active Fire Curtain Barrier Assembly as an 'overlapped' construction using EFP™ A1 fabric
Product Standard:	BS 8524-1:2013
Fire Resistance:	120 minutes Integrity (E) and 30 minutes Radiation (W) performance to BS EN 1634-1:2014 (BS EN 1363-1:2012 & BS EN 1363-2:1999)
Classification:	E15, E20, E30, E45, E60, E90 and E120, plus EW20 and EW30 to BS EN 13501-2:2016
Smoke Leakage:	N/A

*have satisfied the requirements of scheme SDP11-2 this includes evaluation of the product performance in accordance with **BS 8524-1:2013**, inspection of the Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application are detailed in the Schedule referenced below.*



Schedule ref: IFCC 1161/S01
First Issued: 1 September 2015
Revised: 31 October 2019
Valid to: 31 August 2020
Issue No: 3



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK,
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.