



FIRE RESISTANT GLAZED SCREENS

Certificate number: IFCC1193

This is a product certificate to certify that

Takis C Marangos & Sons Ltd

Agios Athanasios Industrial Estate
P.O.Box 54676,
CY-3726 Limassol, Cyprus

Telephone: +357 25724085/6 Fax: +357 25721208
E-mail: info@takismarangos.com

Who fabricate timber fire resisting elements with the following glasses:

**7mm Pyroguard EW30
11mm Pyroguard Maxi EW30 & EW60**

have satisfied the requirements of scheme SDP 09. This includes the testing of products to **BS476: Part 22, EN1363-1 or EN 1364-1** as appropriate, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications and fields of application to achieve from **30 mins to 60 mins integrity** are detailed in the schedule referenced below. As this certificate invokes CF257 it cannot remain valid after the expiry date of CF257.

Schedule ref: IFCC1193/S01



First Issued: 17 December 2015
Reissued: 19 December 2019
Valid to: 16 December 2020
Issue No: 5

A handwritten signature in black ink, appearing to read 'Ian Woodhouse', is written over a light blue horizontal line.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.