



# FIRE RESISTANT TIMBER DOOR SCHEME

***Certificate number: IFCC 1359***

This is a product certificate to certify that

***Andreas Christofi Ltd***

No 6, Reas Street, Tsirion  
Limassol  
Cyprus

Tel: 00357- 25-561684

who fabricate the following timber fire doors:

**Halspan FD30, Halspan FD60, Halspan FD90,  
Halspan FD120  
Strebord FD30, Strebord FD60, Warmsprings FD90**

have satisfied the requirements of the SDP01 Fire resistant Timber Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: HS01, HS02, HS03, HS04, HS05, HS06, SS01, SS02, WSS01



Initial certification: 26 January 2018  
Reissued: 13 February 2019  
Valid to: 25 January 2020  
Issue status: 2



175

Ian Woodhouse  
Director of Certification

IFC Certification Ltd  
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.