

Schedule for:

***Porta Block
152, KARAMANLI Ave,
ACHARNES ATHENS 13678
Greece***

Tel: 00302102832609

Product Name	Configuration	Rating (Integrity)	Test Report Ref
ROCK-15	Single leaf	EI45	01/2015

The Schedule forms an integral part of the certification specifying the scope and field of application for the doors including the configurations, leaf sizes and infills approved together with the hardware, seal and frame specifications which must comply with the doorset as tested in test numbers 01/2015.

Only doors manufactured in accordance with this Schedule complying with the details of test numbers 01/2015 are deemed to be covered by the certification.

This schedule must be read in conjunction with the above-mentioned test reports and all aspects of the specification and limitations defined therein must be satisfied. Failure to comply with all specifications will invalidate the approval and may jeopardise the fire performance.



Ian Woodhouse
Certification Director

Date: 05 September 2018

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd