



FIRE RESISTANT NON-METALLIC DOOR SCHEME

Certificate number: IFCC 1425

This is a product certificate to certify that

Dortek Limited

North Quay, Wicklow Town, County Wicklow,
Ireland

Tel: 00 353 404 60903

who fabricate the following non-metallic fire doors:

Own Design FD120 & FD240 Glazed Single & Glazed Double GRP Doorsets

have satisfied the requirements of the SDP01 Fire Resistant Non-Metallic Door scheme. This includes the testing of products to **BS476: Part 22 & EN1634-1** the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 240 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: IFCC 1425/S01 & S02



Initial certification: 21 January 2019
Valid to: 20 January 2024
Issue status: 1



175

A handwritten signature in black ink, which appears to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.