



FIRE RESISTANT TIMBER GLAZED SCREENS

Certificate number: IFCC1537

This is a product certificate to certify that

A.M. One Visit Solution Ltd.

54 Vasileos Georgiou A Str
Galatex Center
Block B1, Shop 20-24
4047 Limassol
Cyprus

Tel: 00357 25 004718

Who fabricate timber fire resisting elements with the following glasses:

**Pyrobelite 7, Pyrobelite 7 EG, Pyrobelite 10, Pyrobelite 12,
Pyrobel 16, Pyrobel 16 EG, Pyrobel 25, Pyrobel 25 EG**

have satisfied the requirements of scheme SDP 09. This includes the testing of products to **BS476: Part 22, EN1363-1 or EN 1364-1** as appropriate, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications and fields of application to achieve from **30 mins to 60 mins integrity** are detailed in the schedule referenced below. As this certificate invokes CF377 it cannot remain valid after the expiry date of CF377.

Schedule ref: IFCC1537/S01



Initial certification: 13 February 2020
Valid to: 12 February 2021
Issue status: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.