



## **FIRE RESISTANT TIMBER FIRE DOORS**

***Certificate number: IFCC 1080***

This is a product certificate to certify that

### ***Specialized Wood Establishment***

Main Madaba Street  
Al-Yadoudih (beside A-Yadoudih Customs)  
Amman, Jordan  
Tel no.: +9626 412 9119

Who fabricate the following fire doors:

**Halspan FD30, Halspan FD60, Halspan FD90, Halspan FD120  
Halspan 45**

**FireBan FD30, FireBan FD60, FireBan FD90, FireBan FD120**

**Warm Springs FD60, Warm Springs FD90, Warm Springs FD120**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below. Schedule ref: HS01, HS02, HS03, HS04, HS05, HS06, HS07, GTLS03, GTLS04, WS01



First Issued: 14 March 2014  
Re-issued: 2 April 2014  
Revised 05 Sept 2018  
Valid to: 13 March 2019  
Issue No: 3



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse**  
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.