



## **FIRE RESISTANT TIMBER FIRE DOORS**

***Certificate number: IFCC1102***

This is a product certificate to certify that

***Aggelos Charous Ltd***

Klimis Industrial Area Aradippou  
15 Demetras Aradippou  
Larnaca – 7103  
Cyprus

Tel: +357 24 531322

Fax: +357 24 813115

Who fabricate the following fire doors:

**Halspan FD30, Halspan FD60, Halspan FD90,  
Halspan FD120, Strebord FD30, Strebord FD60, Strebord FD90**

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **FD30 to FD120** (30minutes to 120minutes) performance are detailed in the schedules referenced below.

Schedules ref: HS01, HS02, HS03, HS04, HS05, HS06, SS01, SS02, WSS01



First Issued: 8 August 2014  
Re-issued: 02 August 2019  
Valid to: 7 August 2020  
Issue No: 12

A handwritten signature in black ink, which appears to read 'Ian Woodhouse', is written over a light-colored background.

**Ian Woodhouse**  
Director of Certification



**175**

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.