



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1107

This is a product certificate to certify that

Architectural Joinery WLL

(Subsidiary of JAHA International, Hong Kong)

P O Box 32135

Doha, Qatar

Tel no.: +974 4437 6661

who fabricate the following fire doors:

Magmashield FD90

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **90 minutes integrity (FD90)** are detailed in the schedule referenced below.

Schedule ref: IFCC1107/S01



First Issued: 15 October 2014

Re-Issued: 16 December 2019

Valid to: 14 October 2024

Issue No: 4

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse

Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.