



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1220

This is a product certificate to certify that

AS Viljandi Aken ja Uks

**Puidu 6, 71020 Viljandi
Estonia**

Tel.: +372 433 0610

Fax: +372 433 0613

Who fabricate the following fire doors:

FD30/EI30 (FD09) & FD60/EI60 Own Design & FD30/EI30 (FD18)

have satisfied the requirements of the IFCC SDP 01 scheme. This includes the testing of products to **EN1634 -1**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity & insulation** are detailed in the schedules referenced below.

Schedule refs: IFCC 1220 VJ01, VJ02 & VJ03



First Issued: 6th April 2016

Revised: 10th March 2020

Valid to: 5th April 2021

Issue No: 3



175

A handwritten signature in black ink, which appears to read 'Ian Woodhouse'.

**Ian Woodhouse
Director of Certification**

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.