



FIRE RESISTANT TIMBER DOOR SCHEME

Certificate number: IFCC1229

This is a product certificate to certify that

Rhino Doors SIA

Jelgavas iela IM
Daugavpils
LV 5404 Latvia

Tel: + 371 2601 8080

who fabricate the following timber fire doors:

Halspan FD30, FD60, FD90 & FD120
Strebord FD30 & FD60, Warmsprings FD90 & FD120
Blankfort FD30 & FD60, Moralt FD30 & FD60

have satisfied the requirements of the SDP01 Fire resistant Timber Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed on page 2 of this certificate.



First Issued: 25 May 2016
Revised: 10 April 2019
Valid to: 24 May 2021
Issue No: 3



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

F27 ©IFC Certification Ltd 2004

Certificate number: IFCC 1229

The production of fire resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/ Test Report
Halspan Optima	FD30	HS03 PAR/10341/01
Halspan Optima	FD60	HS04 PAR/10341/02
Halspan	FD90	HS05 PAR/10513/01
Halspan	FD120	HS06 PAR/10513/02
Strebord 44	FD30	Chilt/A02066
Strebord 54	FD60	Chilt/A02067
Blankfort	FD30	Chilt/A12151
Blankfort	FD60	Chilt/A12152
Moralt Laminesse Klassik & FireSmoke	FD30	PAR/14247/01
Moralt Laminesse FireSmoke & FireSafe	FD30	PAR/12519/01
Moralt Laminesse FireSmoke & FireSafe	FD60	PAR/12519/02
Moralt Laminesse FireSound	FD30 & FD60	PAR/14559/01
Moralt Laminesse FireSound	FD30 & FD60	PAR/12519/03
Warm Springs	FD60, FD90 & FD120	Chilt/A12138

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.