



FIRE RESISTANT METAL DOOR

Certificate number: IFCC 1467

This certificate certifies that the product below
manufactured by

Navair International Pvt Ltd

59/17, 2nd Floor,
Guru Ravidas Marg Kalkahi Extension,
New Delhi
India
Tel no.: 011 46865000

***Latched single acting double leaf steel
doorset with mineral wool infill and
vision panel***

Satisfy the requirements of the IFCC SDP 02 Fire Resistant Metal Door scheme. This includes the testing of products to **BS476-22: 1987**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to **120 minutes integrity** are detailed in the schedule referenced below.

Schedule ref: IFCC 1467-S01



First Issued: 02 January 2019
Valid to: 01 January 2024
Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.