



ENHANCED SECURITY SINGLE DOORSETS

Certificate number: IFCC 9001

This is to certify that

Phibbs Ltd

239, Kings Henry Drive,
New Addington,
Croydon CR0 0AE

Tel: 01689 844099

Manufacturer of:

Timber Security Doorsets

has successfully completed the requirements of IFCC Enhanced Security Scheme SDSec01. This includes the testing of products to PAS24:2016, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production.

CLASSIFICATION		
SECURITY	WEATHER	STRENGTH
PAS24 DK	BS6357-1 800U	BS6357-2 Medium Duty

The product specification and field of application to achieve this classification are detailed in the schedule referenced below.



Initial certification: 09 January 2017
Revised 03 January 2019
Valid to: 08 January 2022
Issue No.: 2



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification. The reader should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

ENHANCED SECURITY DOORSETS

Certificate number: IFCC 9001

1. This approval relates to the timber security single doorset in providing an enhanced security performance to PAS24:2012 Clauses A.3.2, A.3.3, B.4.3, B.4.4.2, B.4.4.3, B.4.4.4, B.4.5, B.4.6, B.4.8, B.4.9.2.2 and 4.3 a exposure category of 800U to BS 6375-1:2015 and a mechanical strength performance of Medium Duty to BS6375-2/BS EN 1191:2012.
2. The doorsets are approved on the basis of:
 - a. Initial type testing Winkhaus report TR1636.
 - b. Audit testing as specified in IFCC Enhanced Security Scheme document IFCC SDSec 01.
 - c. A design appraisal against SDSec 01 if applicable.
 - d. Ongoing inspection and FPC audits carried out at Phibbs Ltd., 239, Kings Henry Drive, New Addington, Croydon CR0 0AE
3. This approval is applicable to complete doorsets only.
4. This certification is designed to demonstrate compliance of the doorset specifically with the requirements of PAS: 24 and Secured By Design. If compliance is required with any other regulatory or guidance documents then additional requirements may need to be taken into account.
5. This approval is specific to a single leaf, unglazed, opening inwards doorsets without sidelights & toplights, without letter plates at the leaf and frame dimensions given in tables A & B.
6. The approved hardware items for the doorsets are:
 - a. 4 off Euro-spec Enduro hinges
 - b. Winkhaus AV2-F2060/45 92/8 M2 multipoint lock
 - c. Hoppe 92PZ Atlanta Lever/Lever Handle
 - d. Eurospec 35/35 key/turn 1* cylinder CYX71370SC

For the full specification of the product see the IFCC schedule which accompanies this certificate.

TABLE A - Allowable Door Leaf Dimensions

Configuration	Max Door Leaf Width	Max Door Leaf Height	Door Leaf Thickness
None Glazed Single Leaf open-in doorset	926mm	2290mm	44mm

TABLE B – Allowable Frame Dimensions

Configuration	Max Frame Width	Max Frame Height
Single leaf without toplights & sidelights	1020mm	2350mm

Note These maximum dimensions must not be exceeded without separate IFCC approval.



7. The doorsets must be mechanically fixed to the supporting wall construction as described in the manufacturers approved installation instructions as applicable.
8. Labels to the IFCC design referencing the IFCC Certificate IFCC9001, PAS24, applicable rating and manufacturers name, must be affixed to each doorset in the specified position.

Additional information

If you require additional information regarding the certification of this doorset it can be obtained by contacting IFCC