



FIRE RATED DUCTWORK & COMPONENTS SCHEME

Certificate number: FRD600

This is a product certificate to certify that

Firemac Ltd

11 Abbey Road
North Berwick
East Lothian EH39 4BS
Telephone no. +44 (0) 16 2089 2202

Who fabricate the following system

Fabric Based Product For Use in Ductwork Systems

have satisfied the requirements of the SDP 26-1 & SDP 26-2 Fire Resisting Ducts & Components schemes Appendix D. This includes the testing of products to **BS476: Part 24 (ISO 6944: 1985) and EN 1366-1**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **1 hr, 2 hrs and 4 hrs stability, integrity & insulation (BS476: Part 24 - 4 hours) and (EN 1366-1 – 2 hours)** are detailed in the schedules referenced below.



Schedules ref: FRD600/S02, S03, S04,
S05, S06, & S07

First Issued: 20 January 2012

Revised: 25 August 2017

Valid to: 19 January 2021

Issue No: 3

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.