



FIRE RATED DUCTWORK & COMPONENTS SCHEME

Certificate number: IFCC1410

This is a product certificate to certify that

Firemac Ltd

11 Abbey Road
North Berwick
East Lothian EH39 4BS
Telephone no. +44 (0) 16 2089 2202

Who manufacture the following product

Firemac FM Fabric for Use in Firemac FM Fire Duct (EN) Systems

have satisfied the requirements of the SDP 26-2 & SDP 26-3 Fire Resisting Ducts (including smoke extraction) & Components schemes Appendix D. This includes the testing of products to **EN 1366-1, EN 1366-8 & EN1366-9** the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **2 hrs (uninsulated)** to EN 1366-1, EN 1366-8 and EN 1366-9 are detailed in the test reports referenced below.

Test Reports ref: 15/10405-2202, 14/10405-2423,

17/13941-112, LP01 2758 14 Z00NP,

17/13492-111-1, 17/13492-111

First Issued: 09 August 2018

Valid to: 08 August 2023

Issue No: 1



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.