



FIRE RESISTANT TIMBER FIRE DOOR

Certificate number: IFCC 1088

This is a product certificate to certify that

Ghuzlan Emirates Furniture and Décor

P O Box 47051
ICAD 1 Musaffah
Abu Dhabi
UAE

Who fabricate the following systems

Halspan FD30 Halspan FD60 Halspan FD90 Halspan FD120
Fireban FD30 Fireban FD60 Fireban FD90 Fireban FD120
Kingsa FD30 Kingsa FD60 Kingsa FD90 Kingsa FD120
Ghuzlan OD 30 (FD30) Ghuzlan OD 60 (FD60)
Ghuzlan OD 90 (FD90) Ghuzlan OD 120 (FD120)
Strebord FD30 Strebord FD60
Warmsprings FD90 Warmsprings FD120

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes and 120 minutes integrity** are detailed in the schedule referenced below.

Schedules ref: HS01, HS02, HS03, HS04, HS05, HS06, GTL S03, GTL S04, KS01, KS02, KS03, KS04, GH01, GH02, GH03, SS01, SS02, WS02



First Issued: 23 May 2014
Revised: 7th August 2017
Valid to: 22 May 2019
Issue No: 5



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.