



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: FRTD519

This is a product certificate to certify that

ID Project SAL

3rd FLOOR I.C.F. Building
Mkales Main Road
Beirut, Lebanon

Tel: + (961) 1 694 678 Fax: +(961) 1 694 698
E-mail: info@idproject-lb.com Web: www.idplebanon.com

Who fabricate the following fire doors:

Halspan FD30 Halspan FD90
Halspan FD60 Halspan FD120

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01, HS02, HS03, HS04, HS05, HS06



First Issued: 1st October 2010
Re-issued: 3rd February 2017
Valid to: 30th September 2020
Issue No: 3



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.