



FIRE RESISTANT STEEL FIRE DOORS

Certificate number: IFCC 1020

This is a product certificate to certify that

Fire Shield Industry LLC

PO BOX 21605
Ajman
United Arab Emirates
Telephone No. +971(06)7437651

Who fabricate the following fire doors:

Single Action, Double Leaf Steel Doorset FD120

have satisfied the requirements of the SDP02 Fire Resistant Metal Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **120 minutes integrity** are detailed in the schedule referenced below.

Schedule ref: IFCC 1020/S01



First Issued: 23 May 2013
Reissued: 26 March 2018
Valid to: 22 May 2023
Issue No: 3



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.