



PENETRATION & LINEAR GAP SEALS SCHEME

Certificate number: IFCC 1043

This is a product certificate to certify that

Fire Security A/S

Skibasen 20B 4636
Kristiansand
Norway
Telephone no. +47 95 47 80 00

Who manufacture the following system:

Fire Security FS23A Firestop Intumescent Sealant

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 20 & AS1530 Part 4**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to 4 hours fire resistance are detailed in the schedule referenced below.



Schedule No.: PAR/13431/01 & PAR/13933/01
First Issued: 11 October 2013
Revised: 24 July 2015
Valid to: 10 October 2018
Issue status: 3



175

A handwritten signature in cursive script, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.