



PENETRATION & LINEAR GAP SEALS SCHEME SDP13

Certificate number: IFCC 1166

This is a product certificate to certify that

VJ Technology Ltd

Technology House, Brunswick Road,
Cobbs Wood Industrial Estate,
Ashford, Kent
Tel: 01233 652520
TechnicalDept@vjtechnology.com

Who fabricate the following system:

VJT Cast-in 110mm fire collar

have satisfied the requirements of the above scheme. This includes the testing of products to **BS EN 1366-3**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to 4 hours fire resistance are detailed in the schedule referenced below.

Schedule ref: IFCC1166/S01



First Issued: 20 October 2015
Valid to: 19 October 2020
Issue No: 1



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.