



## PRODUCT CERTIFICATION SCHEME SDP11-02

***Certificate number: IFCC/1256***

This is a product certificate to certify that

### **Coopers Fire Ltd.**

Edward House, Penner Road, Havant,  
Hampshire, PO9 1QZ, United Kingdom

#### **Who fabricate the following product:**

<b>Product:</b>	FireMaster® A1 Concertina™ A1 - Active Fire Curtain Barrier Assembly as an 'closed' construction using EFP™ A1 fabric
<b>Product Standard:</b>	BS 8524-1:2013
<b>Fire Resistance:</b>	240 minutes integrity and 30 minutes Radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2016 & BS EN 1363-2:1999)
<b>Classification:</b>	E240 EW30 to BS EN 13501-2:2007+A1:2009

*have satisfied the requirements of scheme SDP11-2 this includes evaluation of the product performance in accordance with **BS 8524-1:2013**, inspection of the Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application are detailed in the Schedule referenced below.*



Schedule ref: IFCC1256/S01  
First Issued: 19 July 2016  
Valid to: 18 July 2021  
Issue No: 1

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK,  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.