



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC1333

This is a product certificate to certify that

Artwood Group S.A.L

Sin El-Fil
Al Qalaa
Naoum Moukarzel Street
Lebanon
Telephone no. +961 (0)1 485401

Who fabricate the following fire doors:

Halspan FD30

Halspan FD60

have satisfied the requirements of the SDP 01 Fire Resistant Timber & Wood Based Door scheme. This includes the testing of products to **EN1634-1**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and extended application report to achieve from **30 minutes to 60 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS08 & HS09



First Issued: 18 Oct 2017
Valid to: 17 Oct 2022
Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.