

***Culimeta-Saveguard Ltd,***  
***CERTIFICATION SCHEDULE***

for

**FIREHALT SF 120 FIRE BARRIER SYSTEM**

This Schedule should be read in conjunction with Certificate No. **IFCC 1334**. It relates to the performance of the Firehalt SF 120 Fire Barrier system as tested in accordance with EN 1364-1: 2015 and recorded in fire test report no. WF 369157.

**1. The following Firehalt SF 120 configurations are approved:**

- Only fire barriers of the same dimensions as the tested specimen as described in fire test report no. WF 369157, (3050 mm wide x 3035 mm drop length) fixed in a vertical configuration.
- Supporting frame of 0.8 mm galvanised steel "Metsec" angle to be used (25 mm x 25 mm at sides and base and 25 mm x 50 mm at head) to be fixed at 250 mm centres with M8 bolts to the fire barrier material.
- Fire barrier to be fixed in place with M8 x 115 bolts.
- Sections of fire barrier shall be stapled together with 73/8mm Leg Length steel "Rapid Staples."

**2. No options or changes in dimensions from the tested specimen are approved for the above configurations, the Firehalt SF 120 fire barrier shall be installed as tested.**

- i) The Firehalt SF 120 shall not be installed with penetrations passing through it.
- ii) The Firehalt SF 120 shall not be installed with hatch / door openings.



**Director, IFC Certification**



**Issued: 02 November 2017**

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd

Page 1 of 1