



# FIRE RESISTANT TIMBER DOOR SCHEME

***Certificate number: IFCC 1350***

This is a product certificate to certify that  
***Katilink Parkway Metals & Joinery  
Industries LLC***

P.O. Box 211924, Dubai  
UAE  
Tel: 009714-357-8166

who fabricate the following timber fire doors:

**Halspan FD30, Halspan FD60, Halspan FD90, Halspan  
FD120  
Strebord FD30, Strebord FD60  
FireBan FD30, FireBan FD60, FireBan FD90  
FireBan FD120**

have satisfied the requirements of the SDP01 Fire Resistant Timber Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: HS01, HS02, HS03, HS04, HS05, HS06, SS01, SS02, GTLS03, GTLS04



Initial certification: 20 Dec 2017  
Valid to: 19 Dec 2022  
Issue status: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd  
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.