



FIRE RESISTANT TIMBER DOOR SCHEME

Certificate number: IFCC 1355

This is a product certificate to certify that

Abdulnoor Carpentry

D-Ring Road, Bldg. 256 Office No. 7 New Salata,
P.O. Box 3551,
Doha
Qatar

Tel/Fax: 0097 444671224

who fabricate the following timber fire doors:

**Halspan FD30, Halspan FD60, Halspan FD90, Halspan FD120
Strebord FD30, Strebord FD60, Ramkor FD90**

have satisfied the requirements of the SDP01 Fire resistant Timber Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: HS01, HS02, HS03, HS04, HS05, HS06, HS07, HS08, SS01, SS02,
RA01



Initial certification: 4 January 2018
Valid to: 3 January 2023
Issue status: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.