

Schedule for:

Al Mana Precision Industries

***Building No. 280, Area 81 Street No. 9
Small and Medium Enterprises Area, 1319
Qatar***

Tel: +974 7022-6023

Product Name	Configuration	Rating (Integrity)	Test Report Ref	Sample Ref. In Test Report
Steel Door Rock Wool infill with and without vision MPI FD180	Single Door	FD 180	RJ041-1 (Issued - 11/01/2018)	Sample A
Steel Door Honey Comb infill with and without vision MPI FD120	Single Door	FD 120	RJ041-1 (Issued - 11/01/2018)	Sample B
Steel Door Honey Comb infill with and without vision MPI FD180	Double Door	FD 180	RJ041-2 (Issued - 28/12/2017)	n/a
Steel Door Rock Wool infill with and without vision MPI FD180	Double Door	FD 180	RJ041-3 (Issued - 7/01/2018)	n/a
Steel Door Fully Glazed MPI FD180	Double Door	FD 180	RJ041-4 (Issued - 20/03/2018)	n/a

The Schedule forms an integral part of the certification specifying the scope and field of application for the doors including the configurations, leaf sizes and infills approved together with the hardware, seal and frame specifications which must comply with the doorset as tested in test numbers RJ041-1, RJ041-2, RJ041-3 & RJ041-4

Only doors manufactured in accordance with this Schedule complying with the details of test numbers RJ041-1, RJ041-2, RJ041-3 & RJ041-4 are deemed to be covered by the certification.

This schedule must be read in conjunction with the above mentioned test reports and all aspects of the specification and limitations defined therein must be satisfied. Failure to comply with all specifications will invalidate the approval, and may jeopardise the fire performance.



Ian Woodhouse
Certification Director



Date: 29 January 2018
Revised: 17 October 2019

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd