



FIRE RESISTANT TIMBER DOOR SCHEME

Certificate number: IFCC 1398

This is a product certificate to certify that

Dalton Joinery

Seal Croft Farm
Childsbridge Lane, Seal
Sevenoaks
Kent
TN15 0BY
Tel: 01732 763688

who fabricate the following timber fire doors:

Flamebreak FD30 & FD60

have satisfied the requirements of the SDP01 Fire Resistant Timber Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity** are detailed on page 2 of this certificate.



Initial certification: 06 June 2018
Valid to: 05 June 2023
Issue status: 1



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

F27 ©IFC Certification Ltd 2004

Certificate number: IFCC 1398

The production of fire resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/ Test Report
Flamebreak 30 30 min Doorsets	FD30	FEA/F98164 Rev L
Flamebreak 60 60 min Doorsets	FD60	Chilt/A02141 Rev I

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.