



FIRE RESISTANT TIMBER DOOR SCHEME

Certificate number: IFCC 1422

This is a product certificate to certify that

Viele

Katsika
Ioannina 45500
Greece

Tel: 0030 2651090085

who fabricate the following timber fire doors:

**Halspan FD30, Halspan FD60, Halspan FD90,
Halspan FD120
Strebord FD30, Strebord FD60, Warmsprings FD90,
FD120**

have satisfied the requirements of the SDP01 Fire Resistant Timber Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: HS01, HS02, HS03, HS04, HS05, HS06, SS01, SS02, WSS02



Initial certification: 18 Oct 2018
Valid to: 17 Oct 2019
Issue status: 1

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.