



FIRE RESISTANT TIMBER DOOR SCHEME

Certificate number: IFCC 1506

This is a product certificate to certify that

Leisure Technique Ltd

Saltgrounds Road
Brough, East Yorkshire HU15 1EG

Tel: (+44) 1482 668377

who fabricate the following timber fire doors:

**Halspan FD30, FD60
Flamebreak FD30 & FD60**

have satisfied the requirements of the SDP01 Fire resistant Timber Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity** are detailed on page 2 of this certificate.



Initial certification: 21 June 2019

Valid to: 20 June 2024

Issue status: 1



175

A handwritten signature in black ink, which appears to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

F27 ©IFC Certification Ltd 2004

Certificate number: IFCC 1506

The production of fire resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

| Doorset Description | Fire Rating | Assessment/ Test Report |
|-----------------------------------|--------------------|--------------------------------|
| Halspan Prima 30 min Doorsets | FD30 | FEA/F97174 |
| Halspan Prima 60 min Doorsets | FD60 | FEA/F96103 |
| Halspan Optima 30 min Doorsets | FD30 | CHILT/A01204 |
| Halspan Optima 60 min Doorsets | FD60 | FEA/F01205 |
| Flamebreak 30 30 min Doorsets | FD30 | FEA/F98164 |
| Flamebreak 60 60 min Doorsets | FD60 | Chilt/A02141 |

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.